

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 74236  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38804

1. OWNER Joyce Lohr ADDRESS AT WELL LOCATION  
 MAILING ADDRESS P.O. Box 1062 6425 Mission Road, Fallon, NV 89406  
Fallon, NV 89406

2. LOCATION SE 1/4 NW 1/4 Sec. 18 T 19N N/S R 30E E Churchill County  
 PERMIT NO. 54988 9-051-04 Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	3
Brown Clay		3	10	7
Brown Sand		10	16	6
Brown Clay		16	28	12
Green Clay		28	45	17
Greenish Gray Clay		45	53	8
Gray Sand		53	75	22
Brown sand		75	95	20
Brown Clay		95	113	18
Green Clay		113	130	17
Black Clay		130	136	6
Black sand		136	141	5
Green Sand		141	150	9
Black Clay		150	167	17
Gray sand		167	185	18
Green Clay		185	195	10
Grayish brown Sand		195	200	5
Green Clay		200	213	13
Gray Green Sand		213	225	12
Gray Clay				
Gray sand				
Brown Clay				
Brown sand				
Green Clay				
Gray sand				XX

8. WELL CONSTRUCTION  
 Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
20 Inches 0 Feet 320 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42.2	.250	0	320

Perforations:  
 Type perforation Mill Cut  
 Size perforation 1/8  
 From 170 feet to 230 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

es  No \_\_\_\_\_ feet to 320 feet

WATER LEVEL  
27" feet below land surface  
 \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 \_\_\_\_\_ °F Quality unknown

*Duplicate of  
 log # 74308*

Date started 6/13/97  
 Date completed 6/21/97

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>800</u>		<u>4 hr</u>	

DRILLER'S CERTIFICATION  
 I, ng, Inc. Contractor  
 under my supervision and the report is true to the  
ng, Inc. Contractor

Address P.O. Box 1265 Contractor  
Fallon, NV 89407-1265 Contractor

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1696

Signed [Signature] driller performing actual drilling on-site or contractor

Date 7-5-97