

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 74276  
 Permit No. \_\_\_\_\_  
 Basin 1108-B  
 NOTICE OF INTENT NO. 38914

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Tetra Tech Hawthorne Army Depot ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 180 Howard St Suite 250 Hawthorne Army Base  
San Francisco, CA 94105 1617  
 2. LOCATION Ne 1/4 SW 1/4 Sec. 31 T 9N N/S R 30 E Mineral County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pipe cut off 3.5ft below grade				
Cement pumped from bottom to top				
6" Cement Cap on top of pipe				
USGS 59				
AMRY WELL # 8				

8. WELL CONSTRUCTION

Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	Feet
From _____ To _____		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
3			0	20.7

Perforations:

Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 14.70 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, NV 89407 1265  
 Nevada contractor's license number 29064 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1753 Division of Water Resources, the on-site driller  
 Signed Wayne By driller performing actual drilling on-site or contractor  
 Date 7-30-98

Date started July 8 19 98  
 Date completed July 8 19 98

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

30 AUG 11 11:06 AM  
 STATE ENGINEERING OFFICE