

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 74286
 Permit No. _____
 Basin 101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37730

1. OWNER Richard Kivley ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 11323 Old Oregon Trail 1111 Casa Grande, Fallon, NV 89406
Redding, CA 96003

2. LOCATION SW 1/4 NE 1/4 Sec. 31 T 19N N/S R 28E E Churchill County
 PERMIT NO. 08-631-44 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____

4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	16	16
Brown Clay		16	21	5
Coarse Brown Sand		21	31	10
Fine Brown Sand		31	35	4
Fine Green & gray sand		35	52	17
See next line	X	52	63	11
Brown, White, & Black Coarse Sand				

8. WELL CONSTRUCTION

Depth Drilled 63 Feet Depth Cased 63 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	Feet	To	Feet
<u>10</u>	<u>0</u>	<u>63</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>14.96</u>	<u>.188</u>	<u>0</u>	<u>10</u>
<u>6 5/8 PVC</u>	<u>3.92</u>	<u>.258</u>	<u>0</u>	<u>63</u>

Perforations: Type perforation Saw Cut
 Size perforation 1/8

From 59 feet to 63 feet

From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 63 feet

9. WATER LEVEL

Static water level 13.3 feet below land surface

Artesian flow _____ G.P.M. _____ P.S.I.

Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor

Address P.O. Box 1265 Contractor

Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715

Signed Douglas Parsons
 By driller performing actual drilling on-site or contractor

Date 6-8-98

Date started 5/18/98, 19__

Date completed 5/18/98, 19__

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>		<u>1 hr.</u>