WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74288
Permit No.
Basin 101

NOTICE OF INTENT NO. 37718

1. OWNER Rick Schroeder (ICM Corp.)
MAILING ADDRESS 380 Quail Way
Fallon, NV 89406

ADDRESS AT WELL LOCATION
10655 Lovelock HWY, Fallon, NV 89406

2. LOCATION NE 1/4 NW 1/4 Sec. 11 T 20N N/S R 28E E Churchill County
PERMIT NO. _____ Issued by Water Resources
9-371-83 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black Volcanic Gravel		0	80	80
Brown Clay		80	83	3
Black Sand		83	140	57
Gray Clay		140	160	20
Gray Sand		160	180	20
Brown Clay		180	190	10
Brown Sand		190	230	40
Gray Clay		230	240	10
Gray Sand		240	275	35

Date started 4/25/98, 19__
Date completed 4/28/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12	Inches	0 Feet	275 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	24.96	.250	0	10
8 PVC	7.17	.258	0	275

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 215 feet to 275 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 275 feet

9. WATER LEVEL
Static water level 79 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed [signature] By driller performing actual drilling on-site or contractor
Date 5-26-98

RECEIVED
98 MAY 27 AM 11:03
STATE ENGINEER'S OFFICE