WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74290
Permit No.
Basin

NOTICE OF INTENT NO. 38947

1. OWNER Bob Hammon Construction
MAILING ADDRESS 5075 Alcorn Road
Fallon, NV 89406

ADDRESS AT WELL LOCATION
5405 Vinewood Circle, Fallon, NV 89406

2. LOCATION SE 1/4 SE 1/4 Sec. 19 T 19N N/S R 28E E Churchill County
PERMIT NO. Issued by Water Resources | 008-652-77 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	12	12
Brown Clay		12	18	6
Brown Sand		18	33	15
Brown Silt		33	44	11
Gray Silt		44	53	9
Gray Sand		53	67	14
Gray Clay		67	73	6
Gray Silt		73	90	17
Gray Silt		90	105	15
Gray Sand		105	115	10
Gray Clay		115	123	8
Gray Sand		123	146	23
Brown Sand	X	146	160	14

Date started 8/27/98, 19__
Date completed 8/27/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10	Inches	0 Feet	160 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	14.96	.188	0	10
6 PVC	3.92	.258	0	160

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 157 feet to 160 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 160 feet

9. WATER LEVEL
Static water level 26.2 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1753
Signed Wayne Parsons
By driller performing actual drilling on-site or contractor
Date 9-11-98