

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 74291
 Permit No. 101
 Basin _____



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38916

1. OWNER Mary Kay Kennedy ADDRESS AT WELL LOCATION 1785 Tumbleweed Dr, Fallon, NV 89406
 MAILING ADDRESS 1785 Tumbleweed Dr Fallon, NV 89406

2. LOCATION SW 1/4 NW 1/4 Sec. 19 T 19N N/S R 29E E Churchill County
 PERMIT NO. 008-273-18 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____

4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	12	12
Brown Clay		12	16	4
Brown Fine Sand		16	18	2
Brown Coarse Sand		18	31	13
Fine Green Sand		31	37	6
Black Silt		37	44	7
Black & Green Coarse Sand		44	53	9
Black & Green Silt		53	55	2
Black & Green Coarse Sand		55	81	26
Fine Grey Sand		81	84	3
Black & Green Coarse Sand		84	96	12
Brown Clay		96	98	2
Brown Coarse Sand		98	105	7
Brown Clay		105	107	2
Brown Coarse Sand	X	107	118	11

8. WELL CONSTRUCTION
 Depth Drilled 118 Feet Depth Cased 118 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 118 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	14.96	.188	0	10
6 5/8	3.92	.258	0	118

Perforations:
 Type perforation Saw Cut
 Size perforation 1/8
 From 114 feet to 117 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No From 50 feet to 118 feet

9. WATER LEVEL
 Static water level 22.9 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
 Signed Douglas Parsons
 By driller performing actual drilling on-site or contractor
 Date 9-17-98

Date started 7/17/98, 19
 Date completed 7/17/98, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			