WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74299
Permit No.
Basin 101

NOTICE OF INTENT NO. 389[illegible]

1. OWNER Sandra Grainger
MAILING ADDRESS 150 n Broadway
Fallon, NV 89406

ADDRESS AT WELL LOCATION
1225 Sheckler Cut-Off, Fallon, NV 89406

2. LOCATION NW 1/4 SW 1/4 Sec. 29 T 19N N/S R 28E E Churchill County

PERMIT NO. _____ Issued by Water Resources
8-654-18 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	10	10
Brown Clay		10	13	3
Brown Sand		13	24	11
Brown Clay		24	27	3
Brown Sand		27	38	11
Gray Clay		38	45	7
Black Clay		45	47	2
Gray Sand		47	53	6
Brown Sand	X	53	63	10

Date started 9/11/98, 19__
Date completed 9/11/98, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1 hr.

8. WELL CONSTRUCTION

Depth Drilled 63 Feet Depth Cased 63 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	63	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	14.96	.188	0	10
6 PVC	3.92	.258	0	63

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 60 feet to 63 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55
Placement Method: [X] Pumped [ ] Poured

Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 55 feet to 63 feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed [signature] By driller performing actual drilling on-site or contractor
Date 10-7-98