WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74311
Permit No.
Basin 101

NOTICE OF INTENT NO. 38933

1. OWNER LJ Suffia
MAILING ADDRESS 5620 Riversedge Drive
Fallon, NV 89406

ADDRESS AT WELL LOCATION
5620 Riversedge Drive, Fallon, NV 89406

2. LOCATION SE 1/4 SE 1/4 Sec. 29 T 19N N/S R 28E E Churchill County
PERMIT NO. Issued by Water Resources | Parcel No. 8/551/30 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	24	24
Fine Sand		24	33	9
Brown Coarse Sand		33	47	14
Fine Grey Sand		47	51	4
Black & White Coarse Sand		51	57	6
Fine Grey Silty Clay		57	59	2
Black & White Coarse Sand		59	81	22
Fine Brown Sand		81	89	8
Brown Coarse Sand		89	95	6
Fine Brown Sand		95	109	14
Fine Grey sand		109	113	4
Black & White Coarse Snad		113	121	8
Fine Grey Sand		121	132	11
Black & Green Coarse Sand		132	145	13
Fine Grey Sand		145	156	11
Brown Clay		156	163	7
Fine Brown Sand		163	168	5
Fine & Coarse Brown Sand		168	186	18
Brown Coarse Sand	X	186	195	9

Date started 7/14/98, 19__
Date completed 7/14/98, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 195 Feet Depth Cased 195 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	195 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	14.96	.188	0	10
6 5/8PVC	3.92	.258	0	195

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 190 feet to 193 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 195 feet

9. WATER LEVEL
Static water level 17 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715

Signed Douglas Parsons
By driller performing actual drilling on-site or contractor

Date 9-17-98