WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74315
Permit No.
Basin 16

NOTICE OF INTENT NO. 38945

1. OWNER Karen Streckfus
MAILING ADDRESS 1390 Brush Drive
Fernley, NV 89408

ADDRESS AT WELL LOCATION
1390 Brush Drive, Fernley, NV 89408

2. LOCATION SW 1/4 NW 1/4 Sec. 24 T 20 N/S R 25 E Lyon County
PERMIT NO. _____ Issued by Water Resources
21-371-10 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other _____

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	10	10
Cobbles & Sand		10	19	9
Brown Sand		19	23	4
Sand & Gravel		23	26	3
Clay & Cobbles		26	35	9
Sand & Gravel		35	41	6
Clay		41	44	3
Sand & Cobbles		44	58	14
Brown Clay		58	61	3
Gravel & Sand		61	73	12
Fine Sand		73	78	5
Clay		78	80	2
Brown Clay		80	90	10
Sand		90	103	13
Brown Clay		103	109	6
Brown Sand	X	109	120	11

RECEIVED 98 OCT -9 AM 10:25 STATE ENGINEER'S OFFICE

Date started 8/9/98 , 19__
Date completed 8/10/98 , 19__

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	80	Feet
6	Inches	80	Feet	120	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	80
5		.188	80	120

Perforations:
Type perforation Mill Cut
Size perforation 1/8
From 110 feet to 120 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level _____ feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons
By driller performing actual drilling on-site or contractor

Date 9-11-98