WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74317
Permit No.
Basin 101

NOTICE OF INTENT NO. 38942

1. OWNER Bill Dotson
MAILING ADDRESS 6845 Sierra Way
Fallon, NV 89406

ADDRESS AT WELL LOCATION
6845 Sierra Way, Fallon, NV

2. LOCATION SW 1/4 SW 1/4 Sec. 18 T 19N N/S R 28E E Churchill County
PERMIT NO. Issued by Water Resources | 008-112-25 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	16	16
Brown Clay		16	18	2
Brownish Black Sand		18	50	32
Brown Clay		50	53	3
Green Silt		53	57	4
Gray Sand		57	62	5
Gray Silt		62	68	6
Brown Sand	X	68	80	12

RECEIVED
99 JAN 11 AM 11:34
STATE ENGINEER'S OFFICE

Date started 8/26/98, 19__
Date completed 8/26/98, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	80 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	14.96	.188	0	10
6 PVC	3.92	.258	0	80

Perforations:
Type perforation saw Cut
Size perforation 1/8
From 77 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 80 feet

9. WATER LEVEL
Static water level 9 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons (by driller performing actual drilling on-site or contractor)
Date 12-27-98