

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39790

1. OWNER Bob Con Scott ADDRESS AT WELL LOCATION 4730 Benson Ln  
 MAILING ADDRESS 4250 Rene Hwy Fallon, NV 89406  
 2. LOCATION NE 1/4 NE 1/4 Sec 2 T 18 N/S R 29 E CHURCHILL County  
 PERMIT NO. 006-631-02 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	40	40
CLAY		40	80	40
SAND		80	100	20
CLAY		100	150	50
SAND		150	160	10

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12" Inches 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>	<u>6.265</u>	<u>.562</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation 5/8 + 5  
 Size perforation 1.25'  
 From 15.5 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 15.5 feet to 160 feet

9. WATER LEVEL  
 Static water level 12 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FARRIS DRILLING Contractor  
 Address 1185 PINE Rd Contractor  
Fallon, NV 89406  
 Nevada contractor's license number 43145  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2082  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 7-20-98

Date started 7-13, 1998  
 Date completed 7-13, 1998

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>6</u>	<u>4</u>