

OFFICE USE ONLY
 Log No. 77375
 Permit No. 92B
 Basin. 92B

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40378

1. OWNER Virginia J. Tower ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 615 Oregon Blvd. Reno, Nevada 89506

2. LOCATION NE 1/4 NW 1/4 Sec. 15 T. 21N N/S R. 19 E Washoe County
 PERMIT NO. 080-404-03 Lemmon Valley Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DOMESTIC WELL ABANDONMENT:				
Static Water Level at <u>291 feet</u>				
Total Depth at <u>298 feet</u>				
Equipment used: Support truck, 3 man crew Grout mixer and generator				
Materials used: 75 sacks Portland Cement Type II				
Excavate around casing 3 feet. Brake concrete seal away from casing. Casing could not be pulled. 4 1/2" casing not perforated, cement as is, verbal Matt Dillon, Division of Water Resources Fill casing to surface Cut casing below grade Back-fill excavation and finish at grade				
Location: <u>65 ft S of N boundary</u> <u>35 ft W of E boundary</u>				

8. WELL CONSTRUCTION

Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)
 From To
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation
 Size perforation
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal
 Placement Method: Pumped Poured
 Poured

Gravel Packed: Yes No
 From feet to feet

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Plugging of log # 39400

9. WATER LEVEL

Static water level feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510 Contractor

Nevada contractor's license number 0022549
 issued by the State Contractor's Board

Nevada driller's license number issued by the 908
 Division of Water Resources, the on-site driller

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date December 23, 1998