

OFFICE USE ONLY
 Log No. 74431
 Permit No. 87
 Basin 87

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 00375

1. Consultant: GROUNDWATER RESOURCES CONSULT. Owner: Rick Street
 1. OWNER 6200 E. 14th St., Suite A200 ADDRESS AT WELL LOCATION 2800 Right Hand Canyon Road
Tucson, AZ 85711-4029 Reno, NV 89510
 2. LOCATION NE 1/4 SE 1/4 Sec. 18 T. 22N N/S R. 22 E Washoe County
 PERMIT NO. M/O 431 MW C-5A 077-310-11 Palomino Valley Area C Rocketdyne
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Monitor Well Abandonment				
Total Depth 58.2 feet				
Dry Well				
Equipment:				
Service Truck & 2 man crew				
Grout Pump & mixer				
Materials:				
6 1/2 sacks Portlan Cement Type II				
1. Measure TD				
2. Glue threaded adaptor to existing casing				
3. Fill casing with 5 1/2 sacks neat cement.				
4. Attach discharge line from cement pump to well casing & pump cement @100 PSI squeezing cement through perforations into the surrounding formations using 1 sack. When pressure increases, discontinue pumping.				
5. Remove monument & cut casing off below grade. Back fill with native materials.				
Location:				
48 ft S of N boundry				
175 ft W of E boundry				

8. WELL CONSTRUCTION

Depth Drilled.....Feet Depth Cased.....Feet

HOLE DIAMETER (BIT SIZE)

From To

.....Inches.....Feet.....Feet

.....Inches.....Feet.....Feet

.....Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.50				

Perforations:

Type perforation.....

Size perforation.....

From.....feet to.....feet

From.....feet to.....feet

From.....feet to.....feet

From.....feet to.....feet

From.....feet to.....feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal.....

Placement Method: Pumped
 Poured

Gravel Packed: Yes No

From.....feet to.....feet

Date started..... 11-18-98 19.....
 Date completed..... 11-18-98 19.....

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Plugging of log
 # 38876

9. WATER LEVEL

Static water level.....feet below land surface

Artesian flow.....G.P.M.....P.S.I.

Water temperature.....°F Quality.....

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date December 1, 1998