

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTEREST NO. 3336  
 984 E Stillwater

1. OWNER Smitten oil ADDRESS AT WELL LOCATION Fallon NV  
 MAILING ADDRESS PO Box 1235  
 Fallon NV

2. LOCATION SE 1/4 NE 1/4 Sec 31 T 19 N/S R 29 E Church Hill County  
 PERMIT NO. 110-579 A & B APN 07-711-10  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>well was in good condition After I took well cover off then I over drilled casing to then pressed grout to the surface</u>	<u>7.2</u>			

8. WELL CONSTRUCTION  
 Depth Drilled 17 1/2 Feet Depth Cased 17 1/2 Feet

HOLE DIAMETER (BIT SIZE)  
 From 6 Inches 0 Feet 17 1/2 Feet  
 To 6 Inches 0 Feet 17 1/2 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12</u>	<u>PVC</u>	<u>0.20</u>	<u>0</u>	<u>17 1/2</u>

Perforations:  
 Type perforation Factory  
 Size perforation 0.20  
 From 15 feet to 17 1/2 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 17 1/2  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From N/A feet to N/A feet

RECEIVED  
 99 JAN 12 AM 10:48  
 STATE ENGINEERS OFFICE

Date started 8-7, 1998  
 Date completed 8-7, 1998

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>N/A</u>	<u>N/A</u>		

9. WATER LEVEL  
 Static water level 7.2 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature 66 °F Quality N/A

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Andersen Exploration Drilling Contractor  
 Address 1635 Belford Road NV 89509 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 34525  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028 T2  
 Signed Andersen  
 Date 11/17/98