WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74489
Permit No. 47
Basin

NOTICE OF INTENT NO. 40149

1. OWNER DAVID & NANCY BLUNT
MAILING ADDRESS P.O. BOX 2083
ELKO, NV 89803

ADDRESS AT WELL LOCATION
17 MILES EAST OF ELKO - ELBURZ EXIT OF I-80

2. LOCATION NW 1/4 NW 1/4 Sec. 11 T 35N N/S R 57E E ELKO County
PERMIT NO. (Issued by Water Resources) 06-54E-003 (Parcel No.) SPECIAL LANDS (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
SAND & SMALL GRAVEL		2	8	6
BROWN SILTSTONE		8	150	142
BLUE SILTSTONE	X	150	180	30
GREY CLAY		180	200	20

RECEIVED 98 SEP 10 AM 11:02 STATE ENGINEER'S OFFICE

Date started 9/3/98, 19__
Date completed 9/3/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		3

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	200

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	15	.220	+1	200

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 180 feet to 200 feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 122 feet below land surface
Artesian flow ___ G.P.M. ___ P.S.I.
Water temperature ___ °F Quality ___

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 9-8-98