WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74518
Permit No.
Basin 105

NOTICE OF INTENT NO. 28167

1. OWNER Sue Wilson
MAILING ADDRESS Genoa NV.
ADDRESS AT WELL LOCATION Not Assigned Yet
APN # 31-020-65

2. LOCATION NW ¼ NW ¼ Sec. 32 T. 12 ☒ S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) Parcel No. 31-020-65 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	3	3
Brown Clay		3	4	1
Surface Water				
DG Sand and DG		4	17	13
Cobbles				
Course DG Sands		17	63	46
Small DG Sands		63	110	47
with Pea Gravels				
Rusty Stained Granite		110	150	40
Fractures of DG				
Sands				
Gray Clay		150	165	15
Course DG Sands		165	190	25
DG Gravels		190	205	15
Gray Gummy Clay		205	215	10
Larger DG Sand and	XXX	215	260	45
Gravels Rusty and				
Green Stratas.				

Date started 10-26, 1998
Date completed 10-30, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35+	45	3 Hrs

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	260 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	15.75	.188	0	260

Perforations:
Type perforation Mill Slot
Size perforation 3X332
From 110 feet to 150 feet
From 170 feet to 190 feet
From feet to feet
From 220 feet to 260 feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 260 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. 35+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat Dr. (Contractor)
Carson City NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael Hall (By driller performing actual drilling on site or contractor)
Date 11/3/98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627