WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74531
Permit No. ~~43~~ 42
Basin

NOTICE OF INTENT NO. 4[illegible]67

1. OWNER **CLARK & NADINE NICOLAY**
MAILING ADDRESS **HALLECK, NV**

ADDRESS AT WELL LOCATION **SO. SIDE OF PINTAIL BETWEEN 4TH & 5TH ST.**

2. LOCATION **SE** 1/4 **NE** 1/4 Sec. **3** T **36N** N/S R **58E** E **ELKO** County
PERMIT NO. _____ Issued by Water Resources | **19-008-010** Parcel No. | **HUMBOLDT ACRES #2** Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
SILTSTONE		2	100	98
BLUE CLAY	X	100	260	160
SILTSTONE & GRAVEL	X	260	280	20

Date started **10/9/98**, 19__
Date completed **10/12/98**, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		6

8. WELL CONSTRUCTION
Depth Drilled **280** Feet Depth Cased **280** Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	180	Feet
6 1/8	Inches	180	Feet	280	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	15	.220	+1	160
6 5/8	12	.188	160	180
4.5	11	.250	160	280

Perforations:
Type perforation **MILLSLOT**
Size perforation **3/16 X 3**
From **160** feet to **180** feet
From **250** feet to **280** feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal **50**
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From **50** feet to **180** feet

9. WATER LEVEL
Static water level **44** feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Hackworth Drilling, Inc.** Contractor
Address **P.O. Box 850** Contractor
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board **020582**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1689**

Signed [signature] By driller performing actual drilling on-site or contractor
Date 10-15-98