WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74543
Permit No.
Basin 42

NOTICE OF INTENT NO. 40177

1. OWNER FRED KELSEA
MAILING ADDRESS P.O. Box 347
Elko, NV 89824

ADDRESS AT WELL LOCATION SW CORNER OF SCAUP & 5TH ST.

2. LOCATION SE 1/4 SE 1/4 Sec. 3 T 36N N/S R 58E E Elko County
PERMIT NO. | Issued by Water Resources | 19-016-010 Parcel No. | Humboldt Acres #2 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	
SANDY SOIL		2	12	10
BROWN SILTSTONE		12	80	68
BLUE SILTSTONE	X	80	100	20
DARK BLUE CLAY		100	120	20

RECEIVED 98 DEC 29 AM 9:59 STATE ENGINEER'S OFFICE

Date started 11/12/98, 19__
Date completed 11/12/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		2

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	15	.225	+1	100
6 5/8	13	.188	100	120

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 38 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 11/13/98