

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40367

1. OWNER GREGORY J. BROWN ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3485 Clark Drive 4500 Jumbo Grade Way  
Carson City, Nevada 89704 Carson City, Nevada 89704  
 2. LOCATION SE 1/4 NE 1/4 Sec. 5 T. 16N N/S R. 20 E. Washoe County  
 PERMIT NO. 050-351-58 New Washoe City  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay		0	3	3
Brown weathered volcanic rock		3	18	15
Purple volcanic rock		18	21	3
Gray volcanic rock		21	31	10
Brown volcanic rock		31	35	4
Gray volcanic rock		35	41	6
Brown hard volcanic rock		41	96	55
Gray clay		96	119	23
Weathered granite		119	141	22
Rusty weathered granite		141	169	28
Weathered gray granite		169	218	49
Fractured granite	X	218	238	20
Weathered granite		238	250	12

8. WELL CONSTRUCTION  
 Depth Drilled 250 Feet Depth Cased 250 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 250 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	250

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 205 feet to 245 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 feet  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 250 feet

9. WATER LEVEL  
 Static water level 59 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 15 P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO., NEVADA 89510  
 Nevada contractor's license number 0022549  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 923  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date February 23, 1999

Date started 2-16-99, 19  
 Date completed 2-22-99, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>		

RECEIVED  
 99 FEB 25 PM 12:48  
 STATE ENGINEERING DIVISION