


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 74564  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_



NOTICE OF INTENT NO. 10318

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **Bob Wunderlich** ADDRESS AT WELL LOCATION **#25 Daney Road Dayton, Nv 89403**  
 MAILING ADDRESS **PO Box 1003 Dayton, NV 89403**  
 2. LOCATION **NE** 1/4 **SE** 1/4 Sec. **28** T. **16** N/S R. **21** E **Lyon** County  
 PERMIT NO. **16-151-59** Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Light brown sandy D.G.		0	5	
Weathered granite		5	10	5
Brown sandy clay		10	25	15
Purple granite		25	27	2
Weathered granite		27	29	2
Purple & brown granite		29	40	11
Multi colored granite		40	44	4
Purple & white fractured granite			70	26
Blue & gray fractured granite		70	175	105
T.D. 175'				

8. WELL CONSTRUCTION  
 Depth Drilled **175** Feet Depth Cased **175** Feet  
 HOLE DIAMETER (BIT SIZE)  

Inches	From	To	Feet
10 5/8	0	100	Feet
8 1/2	100	175	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	17.0	.225	+ 1 1/2	175

Perforations:  
 Type perforation **factory sawed**  
 Size perforation **3/32 x 3**  

From	To	feet to
155	175	feet
		feet

Surface Seal:  Yes  No  
 Depth of Seal **100**  
 Placement Method:  Pumped  Poured  
 Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From **100** feet to **175** feet

9. WATER LEVEL  
 Static water level **25'** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **cold** °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **A.S.A.P. Pump & Well Service, Inc.** Contractor  
 Address **PO Box 60130** Contractor  
**Reno, Nv 89506**  
 Nevada contractor's license number issued by the State Contractor's Board **35387-A**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2066**  
 Signed *Larry Welch*  
 By driller performing actual drilling on-site or contractor  
 Date **2/17/99**

Date started **2/15/99**, 19\_\_\_\_  
 Date completed **2/17/99**, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<b>20+</b>		<b>2 hours</b>
<i>deposited by well log 119585</i>			

RECEIVED  
 99 FEB 24 AM 10:36  
 STATE ENGINEERS OFFICE