REPORT NO. 99.07

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO: 74587
PERMIT NO.
BASIN: 76

NOTICE OF INTENT NO. 40464

1. OWNER Bob & Claire Morrow
MAILING ADDRESS PO Box 205 Wells, Nv 89835
ADDRESS OF WELL 106 School St
Wadsworth, Nv 89442

2. WELL LOCATION NW 1/4 NW 1/4 SEC. 3 T. 20N R 24 E Washoe COUNTY

PERMIT NO _____ PARCEL NO 084-200-35 SUBDIVISION NAME _____

3. TYPE OF WORK: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE: [ ] Cable [X] Rotary [ ] RVC [ ] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Gravels & dirt		0	10	10
Cobbles		10	20	10
Boulders & cobbles		20	40	20
Gravels		40	75	35
Clay		75	100	25
Boulders & gravels	X	100	158	58

RECEIVED 99 FEB 23 AM 11:30 STATE ENGINEER'S OFFICE

Notes: Bottom of borehole full of native material. 5' of gravel in bottom of casing.

Date Started 2/12/99 Date Completed 2/16/99

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		1

8. WELL CONSTRUCTION

Depth Drilled 158 Depth Cased 155

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 100 Feet
8 1/2 Inches 100 Feet 158 Feet
Inches Feet Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+1.5	155

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 135 Feet to 155 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 102'
SEAL TYPE: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
PLACEMENT METHOD: [X] Pumped [ ] Poured

GRAVEL PACKED: [X] Yes [ ] No
From 102 Feet to 155 Feet

9. WATER LEVEL

Static Water Level 40 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
Address 675 Edison Way
Reno, Nv 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 1981

Signed [signature]
By driller performing actual drilling on site or contractor

Dated February 18, 1999

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

REPORT NO. 99-07

NOTICE OF INTENT NO. 40464

1. OWNER Bob & Claire Morrow ADDRESS OF WELL 106 School St
MAILING ADDRESS PO Box 205 Wells, Nv 89835 Wadsworth, Nv 89442
2. WELL LOCATION NW ¼ NW ¼ SEC 3 T 20N R 24E B Washoe COUNTY
PERMIT NO. PARCEL NO. 064-200-35 SUBDIVISION NAME

3. TYPE OF WORK: [X] New Well [ ] Replacement [ ] Deepening [ ] Reconditioning [ ] Abandon [ ] Other
4. PROPOSED USE: [X] Domestic [ ] Municipal/Industrial [ ] Irrigation [ ] Monitor [ ] Test [ ] Stock
5. WELL TYPE: [ ] Cable [X] Rotary [ ] Air [X] Mud

6. WELL CONSTRUCTION
Depth Drilled 158 Depth Cased 155
HOLE DIAMETER (BIT SIZE)
10 5/8 Inches 0 Feet 100 Feet
8 1/2 Inches 100 Feet 158 Feet
Inches Feet Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	188	+4.5	155

PERFORATIONS
Type Perforation Factory Size Perforation 3/32 x 6
From 135 Feet to 155 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No SEAL TYPE: [X] Neat Cement [ ] Cement Grout
Seal Depth 102'
PLACEMENT METHOD: [X] Pumped [ ] Poured [ ] Concrete Grout

GRAVEL PACKED: [X] Yes [ ] No
From 102 Feet to 155 Feet

9. WATER LEVEL
Static Water Level 40 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
I certify that the data contained in this report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 575 Edison Way
Reno, Nv 89502
NV CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 1981
Signature
Dated February 18, 1999

7. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Gravels & dirt		0	10	10
Cobbles		10	20	10
Boulders & cobbles		20	40	20
Gravels		40	75	35
Clay		75	100	25
Boulders & gravels	X	100	158	58

Notes: Bottom of boreholes full of native material. 5' of gravel in bottom of casing.

Date Started 2/4/99 Date Completed 2/4/99

WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Develop

GPM	DRAWDOWN	TIME (HRS)
20+		