WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74542
Permit No.
Basin 49

NOTICE OF INTENT NO. ~~MW-1198~~

1. OWNER Peter A. Herrera
MAILING ADDRESS PO Box 57
ELKO NV 89803

ADDRESS AT WELL LOCATION 777 Idaho Street
ELKO, Nevada

2. LOCATION SE ¼ SE ¼ Sec. 14 T. N 34 N/S R. E 55 E. ~~15 dd~~ County
PERMIT NO. 001-272-001 → Issued by Water Resources | Parcel No. | Subdivision Name

MW-1178

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG Energy MW 02

Material	Water Strata	From	To	Thickness
Brown Sandy Silt		0	20'	20'
Sandy gravel		20	35	15
Sandy Silt		35	43	8'

8. WELL CONSTRUCTION
Depth Drilled 43 Feet Depth Cased 41.34 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8¼ Inches		0 Feet	43 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		PVC	0	33

Perforations:
Type perforation Pre Slotted PVC
Size perforation 0.02
From 33 feet to 41.34 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 33' feet to 43' feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

Date started 12/15/ , 1998
Date completed 12/15/ , 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PC Exploration (Contractor)
Address 900 South 770 West (Contractor)
Woods Cross UT 84087
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1844
Signed James E. Stover (By driller performing actual drilling on site or contractor)
Date 3/1/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627