WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74612
Permit No.
Basin 01

NOTICE OF INTENT NO. 1

1. OWNER AKINS CONSTRUCTION
MAILING ADDRESS 2160 RICE ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION 5730 RIVERSEDGE

2. LOCATION SE 1/4 NW 1/4 Sec. 29 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. (Issued by Water Resources) 855127 Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	19	
BROWN CLAY		19	21	2
BROWN SAND		21	39	18
GREY SAND		39	59	20
BLACK SILTY CLAY		59	85	26
GREY SAND		85	98	13
BROWN SAND		98	101	3
BROWN SAND		101	112	11
GREY SILT		112	118	6
BLACK SILTY CLAY		118	145	27
BLACK CLAY		145	158	13
GREY CLAY		158	159	1
BROWN SAND & GRAVEL	X	159	170	11

Date started 10/20/98, 19__
Date completed 10/20/98, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50+		1 HR

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/4	Inches	0	Feet	100	Feet
6 5/8	Inches	100	Feet	170	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	170

Perforations:
Type perforation MACHINE SLIT
Size perforation .080
From 164 feet to 168 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO DRILLING CORP (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed
By driller performing actual drilling on-site or contractor
Date 10/20/98

USE ADDITIONAL SHEETS IF NECESSARY