WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74615
Permit No.
Basin 101

NOTICE OF INTENT NO. 39635

1. OWNER MIKE CASEY
MAILING ADDRESS 1550 S. ALLEN ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION 1910 PATTI FALLON, NV 89406

2. LOCATION NW 1/4 NW 1/4 Sec. 20 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources
8-172-21 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	13	
BROWN CLAY		13	18	5
BLACK SAND		18	29	11
GREY SAND		29	50	21
GREY CLAY		50	56	6
GREY SAND		56	70	14
GREY CLAY		70	80	10
BLACK CLAY		80	84	4
BLACK SAND	X	84	98	14

RECEIVED 99 FEB 10 AM 10:30 STATE ENGINEERS OFFICE

Date started 12/4/98 , 19__
Date completed 1/29/99 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR BLOWN	20		

8. WELL CONSTRUCTION
Depth Drilled 98 Feet Depth Cased 98 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6 1/4	Inches	50	Feet	98	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	98

Perforations:
Type perforation MACHINE PERF
Size perforation .080
From 93 feet to 97 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 FT
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 11 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name JESUS MARRIEZCURRENA Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed Jesus Marriezcurrena By driller performing actual drilling on-site or contractor
Date 01/29/99

USE ADDITIONAL SHEETS IF NECESSARY