

Log No. 74616


Permit No. _____

Basin 101

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 216



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER JEFF BRADLEY
 MAILING ADDRESS 4720 SODA LAKE ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION 4720 SODA LAKE ROAD

2. LOCATION NW 1/4 NW 1/4 Sec. 4 T 19 N/S R 28 E CHURCHILL County

PERMIT NO. _____ Issued by Water Resources Parcel No. 8-052-61 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BLACK SAND		0	10	
BLACK CLSAY		10	15	5
GREY SAND		15	30	15
BLACK SAND		30	60	30
BLACK SILT		60	70	10
GREY SAND		70	90	20
GREY CLAY		90	100	10
BLACK GRAVEL		100	120	20
BLACK SILT	X	120	130	10

8. WELL CONSTRUCTION

Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

	From	To	
<u>10 3/4</u> Inches	<u>0</u> Feet	<u>50</u> Feet	
<u>6 1/4</u> Inches	<u>50</u> Feet	<u>130</u> Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>+2</u>	<u>130</u>

Perforations:

Type perforation MACHINE SLOT
 Size perforation .080
 From 100 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50 FT
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 15.6 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name JESUS MARIEZCURRENA Contractor
 Address P. O. BOX 888 Contractor
FALLON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
 Signed Jesus Mariezcurrena
 By driller performing actual drilling on-site or contractor
 Date 01/29/99

Date started 12/7/98, 19____
 Date completed 1/9/99, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR BLOWN</u>	<u>30</u>		

RECEIVED
 99 FEB 10 AM 10:30
 STATE ENGINEERING OFFICE