WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74617
Permit No.
Basin 160

NOTICE OF INTENT NO. 56219

1. OWNER GETTO CONSTRUCTION
MAILING ADDRESS 1794 TUMBLEWEED
FALLON, NV 89406

ADDRESS AT WELL LOCATION 5383 OAKWOOD

2. LOCATION SE 1/4 SE 1/4 Sec. 29 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	18	
BROWN CLAY		18	22	4
BROWN CLAY		22	35	13
GREY SAND		35	70	35
GREY CLAY		70	75	5
BLACK GRAVEL		75	89	14
GREY CLAY		89	95	6
BLACK SILT		95	130	35
GREY SAND		130	150	20
GREY CLAY		150	153	3
BLACK SAND	X	153	164	11

99 FEB 10 AM 10:30
WATER RESOURCES OFFICE

Date started 12/7/98, 19__
Date completed 1/9/99, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR BLOWN	30		

8. WELL CONSTRUCTION
Depth Drilled 164 Feet Depth Cased 164 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/4	Inches	0	Feet	100	Feet
6 1/4	Inches	100	Feet	164	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	164

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 159 feet to 163 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 12.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name JESUS MARIEZCURRENA Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed Jesus Mariezcurrena
By driller performing actual drilling on-site or contractor
Date 01/09/99

USE ADDITIONAL SHEETS IF NECESSARY