

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 74641
Permit No. 33B
Basin. 33B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59048

1. OWNER Randee Butoph
MAILING ADDRESS P.O. Box #335
McDermitt N.V.
ADDRESS AT WELL LOCATION 55 Hwy 95 N.
McDermitt N.V.

2. LOCATION NE 1/4 NE 1/4 Sec. 32 T 48 R 38 E Humbolt County
PERMIT NO. 03-521-02
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other ADGER

6. LITHOLOGIC LOG MW# 6

Material	Water Strata	From	To	Thick-ness
<u>SANDY CLAY</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>BROWNISH GREY CLAY</u>		<u>2</u>	<u>20</u>	<u>18</u>

RECEIVED
2 AM 10:45
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)
From 8 Inches To 20 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PVC</u>	<u>SCH 40</u>	<u>0</u>	<u>20</u>

Perforations:
Type perforation FACTORY
Size perforation 5 1020 20
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 3 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No 20 feet

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 74648
Permit No. 33B
Basin. 33B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59048

1. OWNER Randee Butoph
MAILING ADDRESS P.O. Box #335
McDermitt N.V.
ADDRESS AT WELL LOCATION 55 Hwy 95 N.
McDermitt N.V.

2. LOCATION NE 1/4 NE 1/4 Sec. 32 T 48 R 38 E Humbolt County
PERMIT NO. 03-521-02
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other ADGER

6. LITHOLOGIC LOG MW# 5

Material	Water Strata	From	To	Thick-ness
<u>GRAVELY SAND</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>GREY CLAY</u>	<u>6</u>	<u>3</u>	<u>20</u>	<u>17</u>

RECEIVED
99 JAN 12 AM 10:45
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)
From 8 Inches To 20 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PVC</u>	<u>SCH 40</u>	<u>0</u>	<u>20</u>

Perforations:
Type perforation FACTORY
Size perforation 5 1020 20
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 3 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No 20 feet

Date started 10-20, 1998
Date completed 10-20, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

N/A

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 60 °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Andresen Drilling
Address 1635 Bedford Rd
 Reno, N.V. 89509

Nevada contractor's license number issued by the State Contractor's Board 84525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1028T-1

