WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74649
Permit No.
Basin 108

NOTICE OF INTENT NO. 3051

1. OWNER Steve Snyder Lyon Co
MAILING ADDRESS 31 S main st Yerington NV
ADDRESS AT WELL LOCATION Waste Water Treatment Plant Silver Springs NV

2. LOCATION NE ¼ NE ¼ Sec. 19 T. 18 N/S R. 25 E. Lyon County
PERMIT NO. MO 1180 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other gauger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sandy Silt | 26.5 | 0 | 30 | 30 |

RECEIVED 99 JAN 12 AM 10:49 STATE ENGINEER'S OFFICE

Date started 12-7-98, 19
Date completed 12-7-98, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| N/A | | |

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 8 | 0 | 30 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | PVC | SCH 40 | 0 | 30 |
| | | | | |
| | | | | |

Perforations:
Type perforation Fatory
Size perforation .020
From 20 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 15
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 15 feet to 30 feet

9. WATER LEVEL
Static water level 26.5 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andresen Exploration Drilling (Contractor)
Address 1635 Belford rd (Contractor)
Reno NV 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed (By driller performing actual drilling on site or contractor)
Date 12-20-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627