WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74652
Permit No. 65877
Basin 153 X

NOTICE OF INTENT NO. 3911

153 N21E53 DG BDDD1

1. OWNER FRED BAILEY
MAILING ADDRESS BOX 29
EUREKA, NV 89316

ADDRESS AT WELL LOCATION
11TH STREET

2. LOCATION SE 1/4 NW 1/4 Sec. 6 T 21N N/S ~~R 55E~~ E EUREKA County
PERMIT NO. Issued by Water Resources
007-200-01 Parcel No.
R. 53E Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SANDY LOAM | | 0 | 12 | 12 |
| LOOSE SAND & GRAVEL | | 12 | 90 | 78 |
| CLAY | | 90 | 96 | 6 |
| CEMENTED SANDSTONE | | 96 | 160 | 64 |
| LOOSE SAND & GRAVEL | X | 160 | 200 | 40 |

Date started 2/26/99, 19__
Date completed 3/2/99, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| Approx 70 | | 2.5HR |

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 11 | Inches | 0 Feet | 200 Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | 188 | +2 | 200 |

Perforations:
Type perforation MILL SLOT
Size perforation 3/16" X 3"
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 55 feet to 200 feet

9. WATER LEVEL
Static water level 105 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fertig Drilling Company Contractor
Address P.O. BOX 525 Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed Shoel e Fuqua
By driller performing actual drilling on-site or contractor
Date 3-5-99