WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74660
Permit No.
Basin 48

NOTICE OF INTENT NO. 39111

1. OWNER RICHARD EASTWOOD
MAILING ADDRESS BOX 5118
ELKO, NV 89803

ADDRESS AT WELL LOCATION
WASHINGTON & 14TH STREET

2. LOCATION NE 1/4 NE 1/4 Sec. 17 T 32 N/S R 55 E ELKO County
PERMIT NO. Issued by Water Resources
028-001-004 Parcel No.
LUCKY NUGGET #2 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	28	28
HARD FRACTURED ROCK		28	33	5
CLAY		33	40	7
HARD WHITE ROCK		40	345	305
CREAM COLOR CLAY		345	385	40
RED CLAY		385	445	60
RED RYLITE		445	474	29
BROKED RED RYLITE	x	474	532	58

RECEIVED
99 FEB 16 PM 12:43
STATE ENGINEER'S OFFICE

Date started 12/16/98, 19__
Date completed 1/9/99, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
32		3.5 HR

8. WELL CONSTRUCTION
Depth Drilled 532 Feet Depth Cased 532 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	532 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	12.92	188	+2	532

Perforations:
Type perforation MILL SLOT
Size perforation 3/16" X 3"
From 448 feet to 524 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 55 feet to 532 feet

9. WATER LEVEL
Static water level 460 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fertig Drilling Company
Contractor
Address P.O. BOX 525
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed
By driller performing actual drilling on-site or contractor
Date 2-10-99