WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74667
Permit No.
Basin 49

NOTICE OF INTENT NO. 3911 I

1. OWNER DAN MURRY
MAILING ADDRESS 161-15 KITRIDGE CANYON
ELKO, NV 89801

ADDRESS AT WELL LOCATION
9TH STREET & CREE

2. LOCATION NW 1/4 SE 1/4 Sec. 33 T 35 N/S R 55 E ELKO County
PERMIT NO. (Issued by Water Resources) 037018001 (Parcel No.) MEADOW VALLEY RANCHES #5 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARD PAN		0	34	34
BOULDERS/CLAY		34	48	14
WHITE SANDSTONE		48	174	126
WHITE CLAY		174	208	34
WHITE SANDSTONE		208	231	23
SAND & GRAVEL	X	231	252	21

RECEIVED 99 FEB 16 PM 12:43 STATE ENGINEER'S OFFICE

Date started 1/9/99 , 19__
Date completed 1/13/99 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
34		3.5 HR

8. WELL CONSTRUCTION
Depth Drilled 252 Feet Depth Cased 252 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	252 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	188	0	252

Perforations:
Type perforation MILL SLOT
Size perforation 3/16" X 3"
From 230 feet to 252 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 54
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 54 feet to 252 feet

9. WATER LEVEL
Static water level 170 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Company (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed 2-10- [signature] (By driller performing actual drilling on-site or contractor)
Date 2-10-99