

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 74680  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **4013**

OWNER **Bob Hammon**  
 MAILING ADDRESS **4075 Alcorn Road**  
**Fallon, NV 89406**

ADDRESS AT WELL LOCATION **5360 Applewood Drive,**  
**Fallon, NV89406**

2. LOCATION SE 1/4 SE 1/4 Sec. 29 T 19N N/S R 28E E Churchill County  
 PERMIT NO. 008-652-60 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Brown Sand		3	10	7
Brown CLay		10	15	5
Brown Snad		15	18	3
Brown Clay		18	24	6
Brown Snad		24	42	18
Gray Sand		42	55	13
Gray silt		55	57	2
Gray & Black Clay		57	62	5
Gray sand		62	65	3
Brown Sand		65	90	25
Brown Clay		90	97	7
Gray Silt		97	105	8
Gray Clay		105	111	6
Gray Sand		111	116	5
ay Clay		116	130	14
ly Sand		130	150	20
Brown Sand	XX	150	160	10

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 inches To 0 inches  
 From 0 feet To 160 feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 PVC	3.92	.258	0	160

Perforations:  
 Type perforation Saw Cut  
 Size perforation 1/8  
 From 157 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type: \_\_\_\_\_  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 160 feet

9. WATER LEVEL  
 Static water level 22 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1264 Contractor  
**Fallon, Nv. 89407**  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753  
 Signed Wayne Law  
 By driller performing actual drilling on-site or contractor  
 Date 3/1/99

Date started 2/23/99 19\_\_\_\_\_  
 Date completed 2/23/99 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	□ Bailer	□ Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>30</u>		<u>1hr</u>	