WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74690
Permit No.
Basin 49

NOTICE OF INTENT NO. 36627

1. OWNER JERRY BURNER
MAILING ADDRESS 954 EMERALD HILL ROAD
REDWOOD CITY, CA 94061

ADDRESS AT WELL LOCATION
KITRIDGE CANYON ELKO, NV

2. LOCATION NW 1/4 SW 1/4 Sec. 35 T 35N N/S R 55E E ELKO County
PERMIT NO. (Issued by Water Resources) 037052004 (Parcel No.) MEADOW VALLEY RANCHES #5 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LOAM		0	5	5
CLAY		5	40	35
SAND & GRAVEL	X	40	85	45
WHITE SANDSTONE		85	134	49
SAND & GRAVEL	X	134	158	24
WHITE CLAY		158	192	34

RECEIVED 99 MAR 25 AM 11:24 STATE ENGINEER'S OFFICE

Date started 3/10/99 , 19__
Date completed 3/14/99 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	35		4.0 HR

8. WELL CONSTRUCTION
Depth Drilled 192 Feet Depth Cased 192 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	192	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	12.92	188	+1.5	192

Perforations:
Type perforation MILL SLOT
Size perforation 3/16" X 3"
From 154 feet to 174 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 54
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 54 feet to 192 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fertig Drilling Company (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 3-23-99