WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74691
Permit No.
Basin

NOTICE OF INTENT NO. 40129

1. OWNER Martin Enterprises
MAILING ADDRESS 1600 Lattin Road
Fallon, NV 89406

ADDRESS AT WELL LOCATION 5770 Bottom Road,
Fallon, NV 89406 AKA 865 Sam Atha Cir

2. LOCATION SE 1/4 SE 1/4 Sec. 30 T 19N N/S R 28E E Churchill County
PERMIT NO. (Issued by Water Resources) Parcel No. 8-653-44 Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Gravel		0	15	15
Brown Clay		15	27	12
Brown Sand		27	50	23
Green Silt		50	55	5
Gray Clay		55	68	13
Brown CLay		68	74	6
Brown Sand	XX	74	106	32

Date started 2/24/99, 19__
completed 2/24/99, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1hr

8. WELL CONSTRUCTION

Depth Drilled 106 Feet Depth Cased 106 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	106	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 PVC	3.92	.258	0	106
8 5/8	14.96	.188	0	10

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 103 feet to 105 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 106 feet

9. WATER LEVEL

Static water level 15.8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling,Inc. (Contractor)
Address P.O. Box 1264 (Contractor)
Fallon, Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 3/22/99

USE ADDITIONAL SHEETS IF NECESSARY