


STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 74695

Permit No. _____

Basin 101



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40126

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER **Frank Woolsey**
 MAILING ADDRESS **2161 W Williams Ave #280**
Fallon, NV 89406

ADDRESS AT WELL LOCATION **4115 Raven Drive,**
Fallon, NV 89406

2. LOCATION NW 1/4 NW 1/4 Sec 27 T 19N N/S R 28E E Churchill County
 PERMIT NO. _____
 Issued by Water Resources _____ Parcel No. 8-281-48 Subdivision Name _____

3. WORK PERFORMED

- New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE

- Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

- Cable Rotary RVC
 Air Other _____

LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	10	10
Brown Clay		10	14	4
Brown Sand		14	18	4
Brown Clay		18	24	6
Brown Sand		24	34	10
Brown CLay		34	41	7
Gray Clay		41	58	17
Brown Sand		58	70	12

8. WELL CONSTRUCTION

Depth Drilled 70 Feet Depth Cased 70 Feet

HOLE DIAMETER (BIT SIZE)

From 10 Inches To 70 Feet
 From 0 Feet To 70 Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 PVC</u>	<u>3.92</u>	<u>.258</u>	<u>0</u>	<u>70</u>
<u>8</u>	<u>14.96</u>	<u>.185</u>	<u>0</u>	<u>10</u>

Perforations:

Type perforation Saw Cut

Size perforation 1/8

From 67 feet to 70 feet
 From _____ feet to _____ feet

Surface Seal: Yes No

Depth of Seal 60

Placement Method: Pumped Poured

Seal Type:

- Neat Cement
 Cement Grout
 Concrete Grout

Gravel Packed: Yes No

From 60 feet to 70 feet

9. WATER LEVEL

Static water level 9' feet below land surface

Artesian flow _____ G.P.M. _____ P.S.I.

Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.

Contractor

Address P.O. Box 1264

Contractor

Fallon, Nv. 89407

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed _____

By driller performing actual drilling on-site or contractor

Date 3/1/99

Date started 2/8/99, 19____
 Date completed 2/10/99, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>1hr</u>	