

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 74696
 Permit No. _____
 Basin 101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 416

1. OWNER Tim Wuth
 MAILING ADDRESS 3000 Nicole Circle
Fallon, NV 89406

ADDRESS AT WELL LOCATION 3000 Nicole Circle,
Fallon, NV 89406

2. LOCATION SE 1/4 NE 1/4 Sec. 6 T 18N
 PERMIT NO. 6-891-41
 Issued by Water Resources Parcel No.

N/S R 29E E Churchill County
 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	15	15
Brown Sand		15	27	12
Gray Clay		27	31	4
Gray Sand		31	37	6
Black Clay		37	41	4
Gray Silt		41	55	14
Black Clay		55	64	9
Gray Sand		64	83	19
Black Clay		83	90	7
Gray Sand		90	100	10
Brown Clay		100	115	15
Brown sand	XX	115	125	10

8. WELL CONSTRUCTION
 Depth Drilled 125 Feet Depth Cased 125 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10</u>	<u>0</u>	<u>125</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 PVC</u>	<u>3.92</u>	<u>.258</u>	<u>10</u>	<u>125</u>
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>0</u>	<u>10</u>

Perforations:

Type perforation Saw Cut
 Size perforation 1/8
 From 120 feet to 125 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 100
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 125 feet

9. WATER LEVEL
 Static water level 10.2 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1264 Contractor

Fallon, Nv. 89407
 Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons
 By driller performing actual drilling on-site or contractor
 Date 3/22/99

Date started 3/17/99, 19____
 Date completed 3/17/99, 19____

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>60</u>		<u>1hr</u>	