

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38864

1. OWNER McGuire's Construction ADDRESS AT WELL LOCATION 1329 Kim Ln.  
 MAILING ADDRESS Gardnerville NV Gardnerville NV

2. LOCATION SW 1/4 SW 1/4 Sec 27 T 14 S R 20 E Douglas County  
 PERMIT NO. 21-063-03 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	2	2
Coarse Sands		2	37	35
DC SANDS SMALL COARSE SANDS		37	63	26
Brown Clay		63	91	28
Clay Seams and small Sands		91	123	32
Coarse SANDS	XX	123	147	24

8. WELL CONSTRUCTION  
 Depth Drilled 147 Feet Depth Cased 147 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 14.7 Feet  
 10 3/4 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/8	13.03	.188	0	147

Perforations:  
 Type perforation M. 11510+  
 Size perforation 3 x 3/32  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 55 feet to 147 feet

9. WATER LEVEL  
 Static water level 29 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 30 P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CAPITAL CITY Well Drilling Contractor  
 Address 20 Kit Kat DR. Contractor  
Carson City NV 89706  
 Nevada contractor's license number issued by the State Contractor's Board 41775  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 905  
 Signed Michael J. Heck  
 By driller performing actual drilling on site or contractor  
 Date 10-29-98

Date started 10-26, 1998  
 Date completed 10-27, 1998

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>25</u>	<u>3 HRS</u>