

REPORT NO. 98.49

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

LOG NO. 74711
PERMIT NO. 88
BASIN _____

NOTICE OF INTENT NO. 39474

1. OWNER Larry & Mary Sondgroth c/o Wayne Banaszek

ADDRESS OF WELL 17830 Maggie Lane

MAILING ADDRESS 7558 Wimbledon Way Reno, Nv 89511

Reno, Nv 89511

2. WELL LOCATION SE 1/4 SE 1/4 SEC. 10 T 17N R 19 E Washoe COUNTY

PERMIT NO _____ PARCEL NO 047-032-08 SUBDIVISION NAME Galena Forest Estates

3. TYPE OF WORK			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	<input type="checkbox"/> Replace	<input type="checkbox"/> Recondition	<input checked="" type="checkbox"/> Domestic	<input type="checkbox"/> Irrigation	<input type="checkbox"/> Test	<input type="checkbox"/> Cable	<input checked="" type="checkbox"/> Rotary	<input type="checkbox"/> RVC
<input type="checkbox"/> Deepen	<input type="checkbox"/> Plug	<input type="checkbox"/> Other	<input type="checkbox"/> Municipal/Industrial	<input type="checkbox"/> Monitor	<input type="checkbox"/> Stock	<input type="checkbox"/> Air	<input checked="" type="checkbox"/> Mud	

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Boulders & cobbles		0	5	5
DG & sand		5	20	15
Small gravels, DG & clay		20	33	13
Boulders & cobbles		33	55	22
Boulders, cobbles, DG & sand		55	58	3
Hard DG		58	78	20
Black rock, brown clay & DG		78	140	62
DG, sand & brown clay		140	205	65
DG		205	285	80
DG & clay		285	290	5
Alluvial fill		290	330	40
Red & black volcanic rock & clay	X	330	385	55

Notes :

8. WELL CONSTRUCTION

Depth Drilled 385 Depth Cased 384

HOLE DIAMETER (BIT SIZE)

12 1/4 Inches 0 Feet 50 Feet
10 5/8 Inches 50 Feet 386 Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
8 5/8	16.94	.188	+2	384

PERFORATIONS:

Type Perforation Factory Size Perforation 3/32 x 3
From 324 Feet to 364 Feet
From _____ Feet to _____ Feet
From _____ Feet to _____ Feet

SURFACE SEAL: Yes No SEAL TYPE:

Seal Depth 50' Neat Cement Cement Grout

PLACEMENT METHOD: Pumped Concrete Grout
 Poured

GRAVEL PACKED: Yes No
From 50 Feet to 384 Feet

9. WATER LEVEL

Static Water Level 169 Feet Below Land Surface
Artesian Flow _____ GPM _____ PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
Address 675 Edison Way
Reno, Nv 89502

DRILLER'S LIC. NO. _____
NV. CONTRACTOR'S LIC. NO. 15291 ON SITE 1981

Signed Roger M. Hilly
By driller performing actual drilling on site or contractor

Dated November 16, 1998

7. WELL TEST DATA

TEST METHOD Bailer Pump Air Develop

	GPM	DRAWDOWN	TIME (HRS)
From <u>178'</u>	<u>30</u>		<u>1.5</u>