

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37938

1. OWNER BRUCE LARSON ADDRESS AT WELL LOCATION 1.5 MILES WEST OF HWY 376 TO LARSON BLVD THEN SOUTH .4 MILES ON EAST SIDE OF LARSON BLVD.
 MAILING ADDRESS PO BOX 1920 ROUND MOUNTAIN NEVADA 89045 County Round Mt. NV
 2. LOCATION SW 1/4 SW 1/4 Sec 4 T 10 N/S R 43 E NYE County
 PERMIT NO. 12-461-23 Subdivision Name LARSON
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BKN CLY		0	4	4
LARGE GRAVEL		4	23	19
BKN CLY		23	31	8
SMALL GRAVEL		31	45	14
BKN CLY		45	50	5
GRAVEL		50	56	6
TAN CLY		56	74	18
SAND & SMALL GRAVEL		74	78	4
TAN CLY		78	118	40
SAND		118	120	2
TAN CLY		120	145	25
GRAVEL	X	145	160	15
GRAVEL & CLY MIXED		160	165	5

8. WELL CONSTRUCTION
 Depth Drilled 165 Feet Depth Cased 165 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 165 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>1.88</u>	<u>+2</u>	<u>165</u>

Perforations:
 Type perforation MILLED
 Size perforation 3" x 18 RAUBIE ROW
 From 145 feet to 165 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
X ENVIRO DIBL
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 18 feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I. _____
 Water temperature COLD °F Quality 600.0

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WOYTEK DRILLING CO. INC. Contractor
 Address 2220 STONE DR. Contractor
RENO NEVADA 89511
 Nevada contractor's license number issued by the State Contractor's Board 024521A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
 Signed Thomas M. Harris
 By driller performing actual drilling on site or contractor
 Date 3-16-99

Date started 3-13, 19 99
 Date completed 3-16, 19 99

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>		<u>4 HRS.</u>