

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37939

1. OWNER BRUCE LARSON ADDRESS AT WELL LOCATION 1.5 MILES WEST OF HWY 376 TO LARSON BLVD THEN 1.5 MILES SOUTH ON EAST SIDE OF LARSON BLVD. Round Mt. NV  
 MAILING ADDRESS PO BOX 1920 ROUND MTN NEVADA 89045  
 2. LOCATION SW 1/4 SW 1/4 Sec 4 T. 10 N/S R. 43 E. N1/4 County Round Mt. NV  
 PERMIT NO. 12-461-24 Parcel No. LARSON Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

| Material                          | Water Strata | From | To  | Thickness |
|-----------------------------------|--------------|------|-----|-----------|
| BRN CLY                           |              | 0    | 3   | 3         |
| GRAVEL                            |              | 3    | 15  | 12        |
| GRAY CLY                          |              | 15   | 21  | 6         |
| SMALL GRAVEL                      |              | 21   | 36  | 15        |
| BRN CLY                           |              | 36   | 46  | 10        |
| GRAVEL                            |              | 46   | 55  | 9         |
| BRN CLY                           |              | 55   | 81  | 26        |
| SAND                              |              | 81   | 83  | 2         |
| TAN CLY                           |              | 83   | 110 | 27        |
| SMALL GRAVEL                      |              | 110  | 118 | 8         |
| TAN CLY WITH SOME GRAVEL STAMBERS |              | 118  | 138 | 20        |
| BOLDERS & LARGE GRAVEL            | X            | 138  | 155 | 17        |
| BRN CLY & GRAVEL MIXED            |              | 155  | 160 | 5         |

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 50 Feet  
8 3/4 Inches 50 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u>       | <u>12.9</u>         | <u>.188</u>             | <u>+2</u>   | <u>160</u> |

Perforations:  
 Type perforation MILLED  
 Size perforation 3" x 1/8" DOUBLE ROW  
 From 140 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 ENVIRO PLUG  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 18 feet below land surface  
 Artesian flow NO G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature 60.0 °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WOYTEK DRILLING CO. INC. Contractor  
 Address 2220 STOWE DR Contractor  
RENO NEVADA 89511  
 Nevada contractor's license number issued by the State Contractor's Board 024521A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442  
 Signed Thomas M. Harris  
 By driller performing actual drilling on site or contractor  
 Date 3-13-99

Date started 3-10 ~~3-15~~ 1999  
 Date completed 3-13 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M.    | Draw Down (Feet Below Static) | Time (Hours) |
|-----------|-------------------------------|--------------|
| <u>60</u> |                               | <u>4 HRS</u> |