


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only

Log No. 2477

Permit No. 10279

NOTICE OF INTEREST NO. 10279



1. OWNER Don Kittilsen
MAILING ADDRESS 45 Starburst Cr
Sparks, NV

ADDRESS AT WELL LOCATION

3235 Eusker Dr

2. Location NW 1/4 SE 1/4 Sec 28 T 21N R 21E Washoe County
PERMIT NO. PARCEL NO. 076-890-19 SUBDIVISION NAME

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	<input checked="" type="checkbox"/> Air	Other	Mud

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Red clay with dark green red brown volcanic cobbles boulders.		0	86	86
Green red yellow brown volcanic rock.		86	394	308
Red volcanic rock.		394	486	92
Green red yellow brown volcanic rock.		486	753	267
White yellow chalky clay stone.		753	985	232
Green yellow red brown volcanic rock.		985	1337	242

8. WELL CONSTRUCTION				
Depth Drilled	1337 feet	Depth Cased	1337 feet	
HOLE DIAMETER (BIT SIZE)				
	From	To		
11 inches	0 feet	85 feet		
8 3/4 inches	85 feet	1337 feet		
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	188	+1 1/2	1337
Perforations::				
Type Perforation	Factory			
Size perforation	3/32 x 3"			
From	1317 feet	to	1297 feet	
From	1297 feet	to	1277 feet	
From		to		
From		to		
From		to		
Surface Seal	<input checked="" type="checkbox"/> YES	No		Seal Type:
Depth of Seal	68 feet			Neat Cement
				Cement Grout
				<input checked="" type="checkbox"/> Concrete Grout
Gravel Packed:	<input checked="" type="checkbox"/> Yes	No		
From	1337 feet	to	68 feet	

10279-10279-10279
 09 MAR 24 AM 11:18
 2021 L Eusker Dr

9. WATER LEVEL
 Static water level 1175 feet below land surface
 Artesian flow 0 GPM 0 P.S.I.
 Water Temperature cold Degrees F Quality

Date started 12-23 -98
 Date completed 2-17 -99

7. WELL TEST DATA				
TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)			Time (hours)
12	125			2
14	162			3

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name McKay Drilling, Inc.
 2290 Pioneer Drive
 Reno, NV 89509
 NV Contractors No. 14170
 NV Driller's Lic (on site) 1511
 Signed Steve McKay
 By driller performing actual drilling on site or contractor
 Date -99