

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39757

1. OWNER BRUCE HOMER ADDRESS AT WELL LOCATION 5276 DESERT HILLS LOOP
 MAILING ADDRESS Fallen, NV
 2. LOCATION NW 1/4 SW 1/4 Sec. 20 T. 19 N/S R. 28 E. Churchill County
 PERMIT NO. 008-176-20 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	8	8
CLAY		8	15	7
SAND		15	50	35
CLAY		50	80	30
SAND		80	90	10

8. WELL CONSTRUCTION
 Depth Drilled 90 Feet Depth Cased 90 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 90 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	3.2	0.280	0	90

Perforations:
 Type perforation 5/8" x 5
 Size perforation 1/8" x 3"
 From 85 feet to 90 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 85 feet to 90 feet

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name FARKIS DRILLING Contractor
 Address PO Box 5205 Contractor
Fallen, NV 89407
 Nevada contractor's license number 43145
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2082
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 3-19-99

Date started 2/24 1999
 Date completed 2/25 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>25</u>	<u>4</u>

RECEIVED
 99 MAR 26 AM 11:55
 STATE ENGINEERS OFFICE