

OFFICE USE ONLY  
 Log No. 74742  
 Permit No. \_\_\_\_\_  
 Basin. 106

NOTICE OF INTENT NO. 98844  
 ADDRESS AT WELL LOCATION: 3218 W. GARDNER CIR.

1. OWNER: Mike Cafano Const. ADDRESS AT WELL LOCATION: 3218 W. Gardner Cir.  
 MAILING ADDRESS: Gardnerville NV. 89410  
 2. LOCATION: SE NE 4 SW 4 & 7 ADDRESS AT WELL LOCATION: Gardnerville NV. 89410  
SE 1/4 SE 1/4 Sec 1 T 10 S R 21 E Douglas County  
 PERMIT NO. 37-550-08 SUBDIVISION NAME: TRE

3. WORK PERFORMED:  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE:  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE:  Cable  Rotary  RVC  Air  Other: Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Large Boulders		0	25	25
Cobbles and Gravels		25	63	38
Coarse Gravels w Clay Seams		63	79	16
Brown Clay		79	125	46
Volcanic Sands and embedded Gravels		125	195	70
Brown Sandy Clay		195	205	10
Large Fractured Gravels and Cobbles		205	230	25

8. WELL CONSTRUCTION  
 Depth Drilled: 235 Feet Depth Cased: 235 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 3/4 Inches To 0 Feet 235 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13-23</u>	<u>1.88</u>	<u>0</u>	<u>235</u>

Perforations:  
 Type perforation: Mill slot  
 Size perforation: 3x7/32  
 From 215 feet to 235 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal: 35  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 55 feet to 235 feet

9. WATER LEVEL  
 Static water level: 150 feet below land surface  
 Artesian flow: \_\_\_\_\_ G.P.M. 25 P.S.I.  
 Water temperature: Cold °F Quality: Good

Date started: 3-25 1999  
 Date completed: 4-1 1999

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>25</u>	<u>40</u>	<u>3 HRS</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name: Capital City Well Drilling  
 Address: 20 Kit Kat Drive Carson City, NV 89706  
 Nevada contractor's license number issued by the State Contractor's Board: 41775  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1905  
 Signed: Michael Mack  
 By driller performing actual drilling on site or contractor  
 Date: 4-6-99