WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74753
Permit No.
Basin 70

NOTICE OF INTENT NO. 40845

1. OWNER Jane Angus
MAILING ADDRESS 4405 T Quarter Circle Rd
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 5540 W. Rosecreek Rd

2. LOCATION S ½ NW 1/4 Sec. 10 T 35 N S R 37 E Humboldt County
PERMIT NO. _____ Issued by Water Resources | 13-092-06 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	9	-86
Clay		9	44	35
sand & gravel w/clay				
stringers		44	95	51
sand & gravel		95	164	69

RECEIVED 99 APR 14 AM 10:08 STATE ENGINEERS OFFICE

Date started 3/31/99 , 19__
Date completed 4/1/99 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 164 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12-3/4 Inches		0 Feet	164 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8-5/8		.188	+1	160

Perforations:
Type perforation single row mill slot
Size perforation 1/8 x 3
From 100 feet to 160 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 70
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 70 feet to 164 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1154 T-1

Signed [signature] (By driller performing actual drilling on-site or contractor)

Date 4/13/99