

OFFICE USE ONLY
 Log No. 74760
 Permit No. 84
 Basin 84

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40329
 664 Ironwood Rd.

1. OWNER Dave & Julie Dudley ADDRESS AT WELL LOCATION Reno, Nevada
 MAILING ADDRESS 1427 E. Street Sparks, Nevada 89431

2. LOCATION SW 1/4 SW 1/4 Sec. 17 T. 22 n N/S R. 21 East Washoe County
 PERMIT NO. 77-210-10 Parcel No. Palomero V. Unit 8 17.2.1.5, parcel 4 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown D G		0	6	6
Weatherd granite				
blk&white sand		6	10	4
Blk & white granite (hard)		10	48	38
blk&white Granite (fractured)		48	100	52
Blk&white granite (hard)		100	200	100
Gray clay (sticky)		200	210	10
Blk&white Granite (hard)		210	225	15
Granite (fractured)		225	250	25
Blk&white granite		250	315	65
Blk&white granite (fractured)		315	450	135
blk&white granite w/litte green rock		450	455	5
blk, white, green granite		455	470	15
blk&white granite (hard)		470	475	5
blk, white, green granite (fractured) x		475	520	45
blk&white granite (hard)		520	525	5
blk&white granite (weatherd-fractured)		525	540	15
Blk&white granite		540	620	80
Blk&white granite xx (fractured)	xx	620	700	80
T.D.		700		

8. WELL CONSTRUCTION
 Depth Drilled 700 Feet Depth Cased 700 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 50 Feet
105/8 Inches
 From 50 Feet To 700 Feet
8 5/8 Inches
 From _____ Feet To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	17.0	.225	+1 1/2	700

Perforations:
 Type perforation Factory sawed
 Size perforation 3/32 x 3

From 460 feet to 480 feet
 From 680 feet to 700 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 700 feet to 50 feet

9. WATER LEVEL
 Static water level 285 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service, Inc. Contractor
 Address P.O. Box 60130 Reno, Nevada 89506 Contractor
 Nevada contractor's license number 0035387-A issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 11-17-98

Date started 10-30-98, 19____
 Date completed 11-10-98, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>		<u>2 hours</u>