WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74770
Permit No.
Basin 89

NOTICE OF INTENT NO. 32699

1. OWNER J. STEWART
MAILING ADDRESS 15 LONESOME POLECAT RD WASHOE VALLEY, NV
ADDRESS AT WELL LOCATION 15 LONESOME POLECAT RD WASHOE VALLEY, NV 89704

2. LOCATION NE ¼ SE ¼ Sec. 26 T. 16 N S R. 19 E WASHOE County
PERMIT NO. 19993 (Issued by Water Resources) 055 310 18 (Parcel No.) NA (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
PASTURE LOAM		0	2	2
SANDY LOAM W MINOR CLAY + GRVL, SMALL BLDR + COBBLES		2	28	26
SAND, SML GRVL, OCC BLDR, COBBLES LACED W LT CLAY		28	110	82
MOD HARD DG	X	110	135	25
SOFT DG, MOSTLY SAND	X	135	155	20
V SOFT DG		155	157	2
HARDER DG		157	165	8
VERY SOFT DG		165	190	25
CONTACT				
HARD DG, W COBBLES + BLDRS CEMENTED GRVL		190	220	30

Date started 12/2, 1998
Date completed 12/17, 1998

RECEIVED 99 MAR 24 AM 11:11 STATE ENGINEER'S OFFICE

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50±		12

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
14	GL	220

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.250	+2	220

Perforations:
Type perforation SAWCUT
Size perforation 3X 3/32
From 155 feet to 215 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 220 feet

9. WATER LEVEL
Static water level 3 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NEVADA DRILLING, INC (Contractor)
Address 75 LEWERS CRK RD (Contractor)
WASHOE VALLEY, NV 89704
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1539
Signed Joe Reisch (By driller performing actual drilling on site or contractor)
Date 3/22/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627