

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53666

1. OWNER WANDA THORNTON ADDRESS AT WELL LOCATION 25 GARDEN  
 MAILING ADDRESS Dayton NV

2. LOCATION N 1/4 N 1/4 Sec. 28 T. 17N N/S R. 22 E. Lyon County  
 PERMIT NO. 19-24222 Parcel No. MARK T. GARDEN EST Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
rock - sand		0	40	40
clay-rock		40	120	80
clay		120	160	40
clay gravel		160	220	60

8. WELL CONSTRUCTION  
 Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 3/4 Inches To 0 Feet 220 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>119</u>	<u>1 8/8</u>	<u>71</u>	<u>220</u>

Perforations:  
 Type perforation factory mill  
 Size perforation 3/32  
 From 170 feet to 220 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 50  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 30 feet to 220 feet

9. WATER LEVEL  
 Static water level 90 feet below land surface  
 Artesian flow NA G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Tom Benedict / Blaine Drilling Contractor  
 Address PO Box 1255 CC NV 89402 Contractor

Date started 4-9-99 1999  
 Date completed 4-15 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>202</u>	<u>NA</u>	<u>2.5</u>

Nevada contractor's license number issued by the State Contractor's Board 46498  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1898  
 Signed Tom Benedict  
 By driller performing actual drilling on site or contractor  
 Date 4-15-99

RECEIVED  
 APR 15 PM 2:41  
 DIVISION OF WATER RESOURCES