

OFFICE USE ONLY
 Log No. 74774
 Permit No. 79
 Basin. I
 NOTICE OF INTENT NO. 24968

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER L. RODRIGUEZ ADDRESS AT WELL LOCATION Near
 MAILING ADDRESS ELKO, NV

2. LOCATION NE 1/4 SE 1/4 Sec. 12 T. 34 N. R. 55 E. ELKO County
 PERMIT NO. N/R Issued by Water Resources LOT 4, BLK A Parcel No. Last Chance Ranch Unit #3 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	1	1
Soft caliche		1	6	5
Rocky clay		6	86	80
Sandy clay	4gpm	86	88	2
Clay		88	111	23
Sandy clay	✓	111	170	59
Clay		170	180	10
T.D. 180 ft.				

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 181 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 111 Feet
8 Inches 111 Feet 180 Feet
 Casing Schedule

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.108</u>	<u>71</u>	<u>180</u>

 Perforations:
 Type perforation TORCH CUT
 Size perforation 7/8 x 5" x 2/ft.
 From 71 feet to 180 feet
 From 85 feet to 128 feet
 From 149 feet to 170 feet
 Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 51
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 51 feet to T.D. 180 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow NE G.P.M. P.S.I.
 Water temperature Cold °F Quality Good

Date started 3-17, 1999
 Date completed 3-24, 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>20</u>	<u>50</u>	<u>2 hrs.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MATH DRILLING Co. Contractor
 Address 203 PINE ST. Contractor
ELKO, NV 89801
 Nevada contractor's license number issued by the State Contractor's Board 10819
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
 Signed James V. Smith
 By driller performing actual drilling on site or contractor
 Date 4-8-99