WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK 23bab

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74775
Permit No.
Basin 13

NOTICE OF INTENT No. 40369

1. OWNER DAVID & SANDRA COX
MAILING ADDRESS 2460 11th Street
Sparks, Nevada 89431

ADDRESS AT WELL LOCATION
1572 Elkhorn Lane
Reno, Nevada 89506

2. LOCATION NE ¼ NW ¼ Sec. 23 T. 22N N/S R. 19 E. Washoe County

PERMIT NO. (Issued by Water Resources) | 079-470-72 (Parcel No.) | Antelope Valley Red Rock Estates #187 (Subdivision Name) Part 4

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Sandy brown clay		1	3	2
Fine brown sand		3	18	15
Sandy brown clay		18	43	25
Soft zone (NO WATER)		43	48	5
Sandy brown clay		48	68	20
Soft zone (NO WATER)		68	73	5
Sandy brown clay		73	110	37
Soft zone (med brown sand)	X	110	121	11
Brown sandy clay		121	129	8
Coarse brown sand	X	129	147	18

Date started 3-30-99, 19
Date completed 4-7-99, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
22+		

8. WELL CONSTRUCTION
Depth Drilled 147 Feet Depth Cased 147 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	147	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	147

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 147 feet

9. WATER LEVEL
Static water level 68 feet below land surface
Artesian flow G.P.M. 22+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed Gary A. Holman
By driller performing actual drilling on site or contractor

Date April 8, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627