

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33419

1. OWNER Donald W. V. Horst ADDRESS AT WELL LOCATION EAST Side Lane Gardnerville, Nev 89410  
 MAILING ADDRESS 8340 Stapleton Ave Las Vegas, Nev 89128-4743 #1 Four Place Lane  
 2. LOCATION SE 1/4 SW 1/4 Sec. 5 T. 9 N/S R. 23 E Douglas County  
 PERMIT NO. 39-040-40 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Rock and yellow clay mix		0	60	60
Yellow sandy clay		60	200	140
gray clay		200	280	80
Sand & gravel	Y	280	315	35
Rock & clay mix		315	355	40
GRAVEL some large rock and coarse sand mix		355	380	

RECEIVED  
 99 APR -9 MID:33  
 STATE ENGINEERING OFFICE

UTM E 0287898  
 N 429218'  
 NAD 27

8. WELL CONSTRUCTION  
 Depth Drilled 380 Feet Depth Cased 380 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0	50 Feet
6 Inches	50	380 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	380

Perforations:  
 Type perforation Factory saw slot  
 Size perforation 3 3/4  
 From 320 feet to 380 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 ft.  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 280 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Edmund Miller Contractor  
 Address P.O. Box 92 Smith, Nev 89430 Contractor  
 Nevada contractor's license number 32166 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718  
 Signed Edmund Miller  
 By driller performing actual drilling on site or contractor  
 Date 3-29-99

Date started March Feb 10 1999  
 Date completed March 27 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	10	3